

Minnehaha County Facilities & Construction

Fairgrounds Armory Roof Replacement 100 N. Lyon Blvd Sioux Falls, SD 57107

Contractor's Bid Date: Wednesday, April 11, 2018 10:15 a.m.

Bid Submittal Location: Minnehaha County Auditor's Office
415 North Dakota Avenue
Sioux Falls, SD 57104

This Addendum is hereby incorporated into and made a part of the original bid documents for the named project as if set forth therein in full.

ADDENDUM NO. 1:

Question #1:

Can power equipment be used for tear off on the upper roof?

Answer #1:

No power equipment shall be used for tear off on the upper roof.

Question #2:

How shall upper roof insulation be attached to deck?

Answer #2:

Insulation shall be adhered to the deck on the upper roof.

Question #3:

What type of cover board is to be used on the lower roof?

Answer #3:

.5 inch High Density ISO cover board shall be used over insulation and mechanically fastened to metal decking on lower roof using manufacturer's recommended fasteners.

All bidders shall acknowledge receipt and acceptance of ADDENDUMS NO. 1-3 by signing the space provided on the proposal form.



500 N. Minnesota Avenue, Sioux Falls, SD 57104
Strong Foundation. Strong Future.
Equal Opportunity Employer and Service Provider

P: (605)367-4241
F: (605)367-7425
minnehahacounty.org

